



Chhatrapati Sambhaji Nagar. Municipal Corporation

FIRE BRIGADE

TELEPHONE NO-2334000-40FAX No-2331444

Outward No: CSMC/FIRE / 140 / 2024

Date:- 16 / 05 / 2024

To,
Principal, Mrs. Eera Sharma,
Tender Care Education Society, Tender Care Home School Building,
Gut No. 35/P, At. Adgaon BK, Ta. & Dist. Chhatrapati Sambhaji Nagar.

Sub: Final Fire NOC is issued to the Principal, Tender Care Education Society Tender Care Home School Building, Gut No. 35/P, At. Adgaon BK, Ta. & Dist. Chhatrapati Sambhaji Nagar.

**Ref:- 1) Your Letter date 22/11/2021
3) Your Letter date 16/03/2023**

**2) Provisional Noc on dated 22/11/2021.
4) CFO Inspection on date 16/03/2024**

With Reference to the above subject **Final Fire NOC is issued to the Principal, Mrs. Eera Sharma, Tender Care Education Society, Tender Care Home School Building, Gut No. 35/P, At. Adgaon BK, Ta. & Dist. Chhatrapati Sambhaji Nagar. Plot area 22400.00 Sq. mtr.**

Owner has paid **Noc Fees Rs 10,000/-** in Fire brigade Receipt No.12008 dated on 06/04/2024.

Sr No	Building Type	Height Of Building	Floors	Area Of Plot	Builtup Area In Sq.m	Noc	Total
1	Tender Care Education Society Tender Care Home School Building,	08.50	G + 1	22400.00	3678.11	10000	10000

Following Fire prevention and Fire protection & Fire Fighting measures subject to the is **Tender Care Education Society Tender Care Home School Building** is provided.

1. Open space all around the building is provided for free movements of fire tender which will carry 25 tons weight capacity.
2. Over head fire water tank of 25000 ltrs capacity with Booster Pump-10 HP-01No, is provided.
3. 01 No. Fire service in let 4 ways incoming is provided.
4. 04Nos. Court Yard Hydrant points around the building lire Hose Pipe -04 Nos /Branch -04 Nos is provided.
5. 01 No. Wet Riser having hydrant point on all floors with Hose Pipe-03 Nos & Branch-03 Nos is provided.
6. 07 Nos. Hose reel of 100 feet on all out lets is provided.
7. Fire Extinguisher of ABC-06 Kg-20 Nos, & Co2 -4.5 Kg-02, MCP-07 Nos. of suitable capacity is provided.

Principal
**Principal
TCH Orchids
The International School
Adgaon, Aurangabad
Maharashtra- 431007**

8. Manually Operated Electric fire alarm System-01/ Manual Call point -07 Nos, Hooter -07 Nos is Provided
9. Main Staircase 2.00 Mtr is Provided.
- 10 This Certificate Shall be treated valid for a period of one year from the date of issue of fire Noc.Noc should be renewed each year.

As per BMC ACT -1949 section 376, Development control Rules of 1983 and Maharashtra Fire prevention & Life safety Measures Act 2006 reference to above subject **Final Fire NOC** is issued to the **Principal, Mrs. Eera Sharma, Tender Care Education Society, Tender Care Home School Building, Gut No. 35/P, At. Adgaon BK, Ta. & Dist. Chhatrapati Sambhaji Nagar.**


Chief Fire Officer
Fire Brigade
Municipal Corporation
Chhatrapati Sambhaji Nagar.

Copy to:- D.D T P. Municipal Corporation, Chhatrapati Sambhaji Nagar


Principal
TCH Orchids
The International School
Adgaon, Aurangabad
Maharashtra- 431007